

Amerex Corporation

P.O. Box 81
Trussville, AL 35173-0081
205.655.3271 p
800.654.5980 f
<http://www.amerex-fire.com>



Subject: XLT Pizza Ovens with/without AVI Hood

Date: November 2, 2017

File: 66.1.C_ XLT Pizza Ovens with/without AVI Hood

To Whom It May Concern:

Amerex recommends the use of our single flow point nozzle, P/N 11982, for the XLT Chain fed Pizza ovens up to 36" wide and 48" long. The nozzle is to be located in the upper corner of the entrance opening and aimed diagonally to the opposite lower corner of the exit opening.

XLT ovens that are between 48" wide and 120" in length are to be covered with an additional nozzle, which is to be placed in the upper corner of the exit, and aimed diagonally at the lower opposite corner of the entrance opening. If ovens are stackable the appliance coverage will apply to each level of stack (i.e. 2 Stacks 48" Long and 36" Wide require 2-P/N 11982 one for each appliance). XLT Ovens may provide a pre-piped option for this configuration using Amerex specific parts only.



Some installations will incorporate the AVI Hood in conjunction with the chain fed XLT Pizza Ovens. It is Amerex's recommendation to require 2-P/N 11982 Plenum Nozzles (one for each filter bank) and 2- P/N 16416 Duct Nozzles. The duct nozzles are aimed toward the vertical upturn of the exhaust duct connection. Please see the attached diagram for aiming and piping configuration. XLT Ovens with hood may provide a pre-piped option for this configuration using Amerex specific parts only.

Please remember that there are no specific UL tests for a chain fed pizza oven. Ovens traditionally are not protected because of their enclosed design. The above recommendations are based on sound fire protection backed by our extensive knowledge of kitchen fire protection and fire testing. Please let us know of any further questions you may have concerning this issue.

Sincerely,
Derek J. Bryant
Amerex Corporation
Applications Engineer/KP & IS
E-mail: derek.bryant@amerex-fire.com
tech.services@amerex-fire.com

Amerex Corporation

P.O. Box 81
Trussville, AL 35173-0081
205.655.3271 p
800.654.5980 f
<http://www.amerex-fire.com>



Amerex Corporation


P.O. Box 81

Trussville, AL 35173-0081

205.655.3271 p

800.654.5980 f

<http://www.amerex-fire.com>



Quality is Behind the Diamond.