

Amerex Corporation

P.O. Box 81
Trussville, AL 35173-0081
205.655.3271 p
800.654.5980 f
<http://www.amerex-fire.com>



Subject: Pressure Fryer
Date: February 20, 2017
File: 0006.1.A_Pressure Fryer

To Whom It May Concern:

Amerex recommends that a pressure fryer measuring up to a maximum of 19" square or round be protected utilizing the Fryer Nozzle, P/N 13729. The nozzle is to be positioned at the front of the appliance, must not obstruct or be obstructed by any of the loading and unloading activity of the appliance and aimed to the middle of the frying area. The height of the nozzle is to be 36 to 42 inches above the appliance's surface.

Currently, there is no Underwriters Laboratories listing test for pressure fryer coverage. This recommendation is based on sound fire extinguishment knowledge. Please note that this coverage is only possible when the fryer's lid is in the fully open position.

If you have any further questions please feel free to contact me at (205)655-3271.

Sincerely,
Derek J. Bryant
Amerex Corporation
Applications Engineer/KP & IS
E-mail: derek.bryant@amerex-fire.com
· tech.services@amerex-fire.com