

Amerex Corporation

P.O. Box 81
Trussville, AL 35173-0081
205.655.3271 p
800.654.5980 f
<http://www.amerex-fire.com>



Subject: Tandoori Clay Oven
Date: February 20, 2017
File: 0009.1.A_Tandoori Oven

To Whom It May Concern:

Tandoori Clay Ovens, are not listed in our UL manual, nor does it have a UL test procedure for this type of appliance.

Amerex believes that the decision whether or not this appliance be protected by a fire suppression system should be addressed by the local authority having jurisdiction. According to the manufacturers specifications. This appliance is an oven not requiring protection by a wet system due to a lack of grease laden vapors. But, it is always the final judgment of the local authority whether a non-UL listed appliance is protected or not.

If the local authority deems that this oven be protected, we recommend the use of our one flow point nozzle, part number 11982 on an oven up to 24" x 24". On an oven up to 32" x 32" you would use nozzle P/N 13729. The nozzle must be placed 24 to 30 inches above the opening on the top of the oven, and it should be placed 6" off the perimeter of the appliance aimed diagonally into the oven's interior. This protection is only viable if the lid to the oven is in the open position.

Please be sure and make all involved parties aware of the fact that a wet system discharge into this type of oven will result in the shattering of the clay pot, if it is being heated at the time.

If you have any further questions please feel free to contact me at (205)655-3271.

Sincerely,
Derek J. Bryant
Amerex Corporation
Applications Engineer/KP & IS
E-mail: derek.bryant@amerex-fire.com
tech.services@amerex-fire.com